

ADDENDUM


CITY OF AMES

PROJECT: 2016 Flood Prone Manhole Rehabilitation

ADDENDUM NUMBER: 3

DATE: May 17, 2016

Carefully read the following changes to the Plans and Specifications for this project. After reading the changes, sign below to acknowledge receipt of this document and return it to the City Clerk's Office (515 Clark Avenue). This receipt form must be submitted prior to the bid opening or with the bid form.



Angela C. Kolz, P.E.
WHKS & Co.

ADDENDUM:

I. THE FOLLOWING ARE REVISIONS TO THE SPECIFICATIONS:

ESTIMATE REFERENCE INFORMATION

Bid Item No. 1.1 MOBILIZATION (LS).

Insert the following paragraph and list: "There are some manholes buried below grade in this project. The deepest manholes may be buried approximately 6' deep. Contractor is responsible for excavating, completing the repairs, and backfilling to match existing conditions at these locations. Contractor shall stay within construction limits shown on the Plans. The following is a partial list of buried manholes. There may be other buried manholes not indicated on the list below.

- SAMH01400 buried 1' deep in field, map sheet 11.
- SAMH01401 buried 1'-2' deep behind curb, map sheet 11.
- SAMH01046 buried 1'-2' deep in street, map sheet 13.
- SAMH01045 buried 0.5' deep in street, map sheet 13.
- SAMH01403 buried 1'-2' deep behind curb, map sheet 13.
- SAMH01307 buried 3'-6' deep in field, map sheet 16.
- SAMH01069 buried 3'-6' deep in field, map sheet 16.
- SAMH01309 buried 3'-6' deep in field, map sheet 17.
- SAMH03754 buried 3'-6' deep in field, map sheet 17.
- SAMH03756 currently exposed and fenced off – 6' deep in field, map sheet 17.
- SAMH03758 buried 3'-6' deep in field, map sheet 17.
- SAMH03738 buried 3'-6' deep in field, map sheet 18.
- SAMH03739 buried 3'-6' deep in field, map sheet 18.
- SAMH03743 buried 3'-6' deep in field, map sheet 18.
- SAMH03745 buried 3'-6' deep in field, map sheet 18."

II. THE FOLLOWING ARE REVISIONS TO THE PLANS: NONE

III. Any revisions to any of the Contract Documents made by this Addendum shall be considered as the same revision to any and all related areas of the Contract Documents not specifically called out in the Addendum.

I hereby acknowledge receipt of this Addendum and recognize that my bid will not be opened unless this signed document is filed in the City Clerk's Office prior to the letting as specified in the notice of public hearing and to bidders, or other contract documents or submitted with my bid.

SIGNED _____

TITLE _____

FIRM _____

DATE _____