

# 2020 Annual Inspection Report Inactive CCR Surface Impoundment



City of Ames Steam Electric Plant

Ames Municipal Electric System  
502 Carroll Avenue  
Ames, Iowa 50010

**SCS ENGINEERS**

Report Number 272220309.00 | April 2021

8450 Hickman Road, Suite 27  
Clive, Iowa 50325  
515-631-6160

April 14, 2021  
File No. 27220309.00

Mr. Brian Trower  
Assistant Director – Electric Services  
Ames Municipal Electric System  
502 Carroll Avenue  
Ames, Iowa 50010

Subject: 2020 Coal Combustion Residuals (CCR) Inactive Surface Impoundment Inspection

Dear Mr. Trower:

SCS Engineers has prepared the 2020 CCR Inactive Surface Impoundment Inspection Report for the City of Ames Steam Electric Plant in general accordance with the requirements set forth in §257.83(b) of the CCR Rule (40 CFR 257.50-107).

If you have any questions regarding this document, please contact the undersigned.

Sincerely,



Jeff D. Phillips  
Project Manager  
SCS ENGINEERS  
(515) 631-6159  
[jdphillips@scsengineers.com](mailto:jdphillips@scsengineers.com)



Christine L. Collier, P.E.  
Project Manager  
SCS Engineers  
(515) 631-6161  
[ccollier@scsengineers.com](mailto:ccollier@scsengineers.com)



## Table of Contents

Section	Page
PE Certification .....	ii
1 INTRODUCTION .....	1
1.1 Purpose.....	1
1.2 Facility Description .....	2
2 REVIEW OF AVAILABLE INFORMATION .....	3
2.1 Operating Record Review .....	3
2.2 Visual Inspection .....	3
3 ANNUAL INSPECTION RESULTS .....	4
3.1 Changes in Geometry.....	4
3.2 Instrumentation and Readings.....	4
3.3 Depth and Elevation of Impounded Water and CCR .....	5
3.4 Storage Capacity .....	5
3.5 Volume of Impounded CCR and Water .....	6
3.6 Structural Weakness or Disruptive Conditions .....	6
3.7 Other Changes Affecting Stability or Operation .....	7
4 REVISIONS, RECORDKEEPING, AND REPORTING .....	8

### Figures

Figure 1 – CCR Site Observation

### Appendices

Appendix A – Site Observation Checklist

Appendix B – Photographs

# PE CERTIFICATION



I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Iowa.

*Christine L. Collier*

(signature)

(date)

Christine L. Collier

(printed or typed name)

License number 17963

My license renewal date is December 31, 2021.

Pages or sheets covered by this seal:

Entire Document

# 1 INTRODUCTION

On April 17, 2015, the United States (US) Environmental Protection Agency (EPA) issued the final rule of the federal Coal Combustion Residuals (CCR) Rule to regulate the disposal of CCR materials generated from the combustion of coal at electric utilities and independent power producers. The initial federal CCR Rule allowed for inactive CCR surface impoundments that had completely closed by April 17, 2018, to have no other requirements applied to that unit (i.e., the “early closure” provisions). However, on June 14, 2016, the United States Court of Appeals for the D.C. Circuit ordered the vacatur of these “early closure” provisions in the Code of Federal Regulations (CFR) 40 Part §257.100. The effect of the vacatur is that inactive CCR surface impoundments must now comply with the requirements applicable to existing CCR surface impoundments. Inactive power plant ash impoundments containing CCR are regulated under 40 CFR Part §257.100.

The City of Ames (City) Ames Municipal Electric System operates a Steam Electric Plant (SEP) located at 200 East 5<sup>th</sup> Street in Ames, Iowa. The inactive CCR surface impoundment (Impoundment) associated with the Ames Municipal Electric System’s SEP is subject to the CCR Rule and in accordance with the rule must be inspected annually by a qualified professional engineer as specified in Section §257.83 of the rule. SCS Engineers (SCS) completed the 2020 annual site inspection of the Ames Municipal Electric System SEP Impoundment on December 9, 2020. This report provides documentation of the requirements in 257.83(b)(1) and (2).

## 1.1 PURPOSE

The purpose of the annual site inspection is to, through observation, ensure that the design, construction, operation, and maintenance of the CCR unit is consistent with recognized and generally accepted good engineering practices. Per 40 CFR §257.83(b)(1), the site inspection must, at a minimum, include:

- A review of available information regarding the status and condition of the CCR unit, operating records files, weekly inspections, structural stability assessments, and results of previous annual inspections - §257.83 (b)(1)(i)
- A visual site inspection of the CCR unit and appurtenant structures to identify signs of distress or malfunction of the CCR unit and appurtenant structures - §257.83 (b)(1)(ii)
- A visual site inspection of any hydraulic structures underlying the base or passing through the dike of the CCR unit for structural integrity and continued safe and reliable operation - §257.83 (b)(1)(iii)
- A site inspection report that includes the following:
  - Changes in geometry since the last inspection - §257.83 (b)(2)(i)
  - Location and type of existing instrumentation and maximum recorded readings since the last inspection - §257.83 (b)(2)(ii)
  - Approximate minimum, maximum and present depth and elevation of impounded water and CCR since the last inspection - §257.83 (b)(2)(iii)

- Storage capacity of the impounding structure at time of inspection - §257.83(b)(2)(iv)
- Approximate volume of impounded water and CCR at the time of inspection - §257.83(b)(2)(v)
- Appearance of actual or potential structural weakness of the CCR unit - §257.83(b)(2)(vi)
- Any other changes which may have affected the stability or operation of the CCR unit since the last inspection - §257.83(b)(2)(vii)

## 1.2 FACILITY DESCRIPTION

The City of Ames owns and operates a full service electric utility d/b/a the Ames Municipal Electric System with generation, transmission, and distribution assets necessary to serve the City. The City owns and operates two generating facilities, the (SEP) and the Combustion Turbine Station. The SEP has two generating units (7 and 8), with nameplate ratings of 33 and 65 megawatts, which went into commercial operation in 1967 and 1982, respectively. Both units were outfitted with pulverized coal boilers providing steam to non-reheat turbine-generators. For fuel, the boilers fired ultra-low sulfur sub-bituminous coal from the Powder River Basin in Wyoming, along with co-firing refuse derived fuel (RDF). In 2016, both units were converted to fire natural gas, while still co-firing RDF. By discontinuing the discharge of CCR to the ash site as of October 19, 2015, the Impoundment qualifies as an “inactive” site under 40 CFR §257.53. RDF has been co-fired in the SEP since 1975.

Placement of CCR into the Impoundment ceased prior to October 19, 2015. The Impoundment continues to be operated by the Ames Municipal Electric System SEP to dispose of the non-CCR ash from the co-firing of RDF in the power plant’s boilers. The RDF ash is transported (sluiced) from the power plant and is discharged into the primary ash pond to allow time for the ash to settle out to clarify the water. Water from the primary pond ultimately flows into a structure with stop-logs connecting the primary ash pond with the first of two clear water ponds. After passing through the two clear water ponds, the water enters the pump house at the southwest corner of the second clear water ponds where it is pumped back to the power plant for reuse as ash transport (sluice) water. There are times in order to best manage the water balance of the pond system that it becomes necessary to decant a portion of the clean return water into the field lying to the south of the pump house and clear water basins.

## 2 REVIEW OF AVAILABLE INFORMATION

Ms. Christine Collier, P.E. and Mr. Jeff Phillips of SCS completed an annual site inspection and review of the Ames Municipal Electric System SEP Impoundment on December 9, 2020, in accordance with 40 CFR §257.83(b)(1). Ms. Collier is a licensed professional engineer in Iowa and holds a Master of Science degree in Civil Engineering. She has over 20 years of experience in the design, construction, and operation of solid waste management facilities.

### 2.1 OPERATING RECORD REVIEW

In accordance with §257.83(b)(1)(i), SCS reviewed the available information in the operating record for the Impoundment in support of the visual observation discussed below. SCS reviewed operating record materials provided by the Ames Municipal Electric System SEP and the information posted on the Ames Municipal Electric System's CCR Rule Compliance Data and Information website for this facility. Compliance documents to meet the April 17, 2018, deadline under §257.100(e)(3)(i), (iv), and (v), §257.100(e)(4)(ii), and §257.100(e)(6)(i) and (ii) were completed as required. Additional specific documents reviewed include, but are not limited to the previous annual site inspection report prepared by SCS Engineers April 14, 2020, and weekly visual inspection logs and monthly instrumentation readings provided by Ames Municipal Electric System SEP.

Review of the above documents did not uncover any unresolved issues that indicated operation, safety, or structural concerns on the Ames Municipal Electric System SEP Impoundment.

### 2.2 VISUAL INSPECTION

SCS visually observed the Impoundment to identify signs of distress or malfunction of the CCR unit and appurtenant structures per §257.83(b)(1)(ii). In addition, a visual observation of the hydraulic structures underlying the base of the CCR unit or passing through the dike of the CCR unit for structural integrity and continued safe and reliable operation of these features per §257.83(b)(1)(iii) was completed for features readily visible from the ground surface. Figure 1 contains the overall site layout, monitoring well locations, site features, and noted areas. At the time of inspection, a contractor was removing buildup of accumulated ash in the western channel of the Impoundment and stockpiling the material within the Impoundment. No sluice water or cooling tower blowdown discharge into the Impoundment was occurring during the inspection. Ames Municipal Electric System continues to prepare to complete a partial clean closure (east portion) and partial close in place (west portion) of the Impoundment.

### 3 ANNUAL INSPECTION RESULTS

The site observation checklist, included in Appendix A, was utilized during the annual site inspection. The overall site layout is shown on Figure 1. Photographs taken to compare the current facility conditions to those during the 2019 site inspection are included in Appendix B. No significant changes were noted in comparison with 2019/2020 photographs. The results of the annual site inspection, along with a description of any deficiencies identified during the visual observation, are further summarized in the following sections in accordance with 40 CFR §257.83(b)(2).

#### 3.1 CHANGES IN GEOMETRY

There were no apparent changes in the geometry of the Impoundment when compared to the previous SCS site inspection report, the historical construction drawings provided by the Ames Municipal Electric System SEP, or the site observation photographs. No significant change to the geometry of the RDF/coal ash material within the Impoundment was observed during the inspection.

#### 3.2 INSTRUMENTATION AND READINGS

Historically there have been three piezometers and one groundwater monitoring well (east of the bike path and lying east of the Impoundment) that are utilized for groundwater level readings. Eight additional groundwater monitoring wells were installed in June 2018. Figure 1 shows the locations of these points. Table 1 below provides a summary of the monitoring points, maximum recorded readings since the previous annual site inspection and the date on which those readings occurred.

Table 1. Instrument Information

Instrument Name <sup>(1)</sup>	Max Reading Since Previous Observation <sup>(2,3)</sup>	Date Recorded
MW-1 <sup>(4)</sup>	54.42	9/18/2020
PZ-1 <sup>(4)</sup>	57.39	7/24/2020
PZ-2 <sup>(4)</sup>	56.68	9/18/2020
PZ-3 <sup>(4)</sup>	56.89	9/18/2020
MW-101 <sup>(4)</sup>	56.41	5/28/2020
MW-102 <sup>(4)</sup>	56.57	5/28/2020
MW-103 <sup>(4)</sup>	56.82	5/28/2020
MW-104 <sup>(4)</sup>	57.03	5/28/2020
MW-105 <sup>(4)</sup>	56.99	5/28/2020
MW-106 <sup>(4)</sup>	56.71	5/28/2020



Instrument Name <sup>(1)</sup>	Max Reading Since Previous Observation <sup>(2,3)</sup>	Date Recorded
MW-107 <sup>(4)</sup>	56.18	5/28/2020
MW-108 <sup>(4)</sup>	55.90	5/28/2020

Notes:

- (1) See Figure 1 for location of monitoring points.
- (2) Groundwater elevation based on local site datum, top of casing based on City survey data from July 2018 and March 2019.
- (3) Elevations shown relate to the Plant Datum. Adjust City survey data by adding (823.549 feet) City Datum to obtain elevations related to Plant Datum.
- (4) Readings taken monthly by Ames Municipal Electric System SEP Staff and during background/semi-annual sample events by SCS staff.

### 3.3 DEPTH AND ELEVATION OF IMPOUNDED WATER AND CCR

The maximum and minimum depths of impounded water frequently change depending on Ames Municipal Electric System SEP operations and rainfall events. The minimum, maximum, and present depth and elevation of the impounded surface water and the CCR since the previous annual site inspection are noted in Table 2 below. Please note that dry CCR is stockpiled above the dike elevation within the western portion of the Impoundment.

**Table 2. Water and CCR Level Information**

	Depth	Elevation	Description
Minimum <sup>(1)</sup>	9.50 <sup>(2)</sup>	68.50 <sup>(2)</sup>	Water level from Ames Municipal Electric System SEP measurements
Maximum <sup>(1)</sup>	11.17 <sup>(2)</sup>	70.17 <sup>(2)</sup>	
Present	10.30 <sup>(2)</sup>	69.30 <sup>(2)</sup>	Water level on date of observation
Current – CCR Level <sup>(3)</sup>	16.70	75.70	Pad elevation at northwest corner of hoop building
	43.45	102.45	Built-up CCR stockpiles within Impoundment – pile located between two sluice channels

Notes:

- (1) Based on water level information provided by Ames Municipal Electric System SEP.
- (2) Depth and elevation at the primary pond outlet structure.
- (3) Based on May 2019 topographical survey by Bolton & Menk.

### 3.4 STORAGE CAPACITY

Based on the grades provided on the Construction Record drawings, Sheet 7 of 14 dated December 1982 by Lutz, Daily & Brain, the storage capacity of the Impoundment to the top of the berm (elevation 74 feet) is approximately 209,262 cubic yards (cy). The storage capacity to the operating level, with three feet freeboard (elevation 71 feet) is approximately 161,995 cy. There have not been

modifications to the Impoundment since the 1982 construction; therefore, these storage capacities remain the same.

### 3.5 VOLUME OF IMPOUNDED CCR AND WATER

The approximate volume of the impounded water and CCR/RDF ash material at the time of the site inspection was 199,936 cubic yards (cy). A bathymetric and topographical survey of the Impoundment was performed by Bolton & Menk in May 2019. Calculations based on the survey information resulted in a total volume of 172,500 cubic yards (cy) of CCR/RDF ash material. The volume of the free water at the time of the bathymetric survey was estimated to be 31,900 cy for a total estimated volume of 204,400 cy. The water level at the time of the bathymetric/topographical survey was 893.91 feet above mean sea level or 70.36 feet by Plant datum. Re-evaluation with the water table at 69.30 feet as noted during the December 2020 inspection provides an estimated total of 23,330 cy of water. In addition, based on estimates provided by Ames Municipal Electric System staff, approximately 2,083 tons of RDF ash material, or 1,736 cy of RDF ash material, were added to the pond in 2020. The volume of impounded CCR and water at the time of the inspection was therefore estimated to be 199,936 cy. Table 3 provides data used to determine the 2020 volume.

**Table 3. Estimated Volume of Impounded Water and CCR**

Source	Quantity	Notes
May 2019 Calculated CCR Ash/RDF Ash Volume	172,500 cy	May 2019 Bolton & Menk bathymetric and topographic survey
May 2019 Calculated Water Volume	31,900 cy	May 2019 Bolton & Menk bathymetric and topographic survey
December 2020 Calculated Water Volume	23,330 cy	Calculated through CADD
2020 RDF Ash/Material Added to Impoundment	1,736 cy	Provided by Ames Municipal Electric System staff
<b>2020 Volume of Impounded CCR and Water</b>	<b>199,936 cy</b>	<b>Approximate based on calculations</b>

### 3.6 STRUCTURAL WEAKNESS OR DISRUPTIVE CONDITIONS

The site inspection included a review of the appearance of an actual or potential structural weakness of the Impoundment. The visual observation included a review for the presence of the conditions listed in Table 4, which also includes items noted during the site inspection.

**Table 4. Site Inspection Item Details**

Site Observation Condition		Comment
Seepage		None noted.
Sloughing, slumping, or sliding		None noted.
Excessive settlement		None noted.
Surface cracking		None noted.
Inappropriate vegetation growth		See comments below.
Animal impacts		See comments below.
Erosion damage		See comments below.
Failing riprap		None noted.
Failing outlet or outfall structures		None noted.
Item Noted	Comment	Action Level
Inappropriate vegetation growth	Trees were noted growing on both the upstream and downstream slopes.	Removal with routine maintenance
Animal impacts	Indications of beavers were noted based on tree marks. There was no observed animal activity in the exterior dikes. Area 1 on Figure 1 denotes area of past observations.	Continued observation
Erosion damage	Erosion noted in southeast corner of Impoundment on the inboard slope. Also noted in the last site observation. Ames Municipal Electric System are in the process of developing a plan for the future of the Impoundment. See Appendix A Checklist Notes, Area 2 on the aerial photograph for approximate area.	Repair with routine maintenance

### 3.7 OTHER CHANGES AFFECTING STABILITY OR OPERATION

Based on the information provided by the Ames Municipal Electric System SEP staff and on-site observation, other change(s) which may have affected the stability or operation of the Impoundment structure since the previous annual site inspection were not observed.

## 4 REVISIONS, RECORDKEEPING, AND REPORTING

This document will be placed in the facility's operating record (§257.105(g)(6)) and on the Ames Municipal Electric System SEP's CCR Rule Compliance Data and Information website (§257.107(g)(5)). The Ames Municipal Electric System SEP will notify the Iowa Department of Natural Resources (DNR) that this report has been completed and placed in the facility's operating record and on the Ames Municipal Electric System SEP CCR Rule Compliance Data and Information website (40 CFR §257.106(g)(5)). The next annual site inspection report is due one year from the completion of this report.

T:\27219426.00\AutoCAD\CCR Site Inspection.dwg Mar 31, 2020 - 4:53pm Layout Name: Fig 1 By: 4277zem



LEGEND:  
 MONITORING WELL OR PIEZOMETER



SHEET TITLE <b>CCR SITE OBSERVATION</b>	REV.	DATE	BY
	△	-	-
PROJECT TITLE <b>2020 ANNUAL INSPECTION REPORT                  INACTIVE CCR SURFACE IMPOUNDMENT</b>	△	-	-
	△	-	-
CLIENT <b>CITY OF AMES MUNICIPAL                  ELECTRIC SYSTEM</b> AMES, IA	△	-	-
	△	-	-
CADD FILE: CCR SITE INSPECTION.DWG	△	-	-
	△	-	-
DATE: <b>4/13/2021</b>	△	-	-
FIGURE NO. <b>1</b>	△	-	-

**SCS ENGINEERS**  
 8450 Hickman Road, Suite 27  
 Clive, IA 50325  
 PH: (515) 631-6160 eFAX: (913) 681-0012  
 PROJ. NO. 27220309.00  
 DSK: JRR  
 DWN. BY: ZEM  
 CHK. BY: CLC  
 O/A RW BY: CLC  
 PROD. MGR: CLC



## Appendix A

### Site Observation Checklist



## Coal Combustion Residuals Impoundment Annual Site Observation Checklist

**Facility Name**  
CCR Ash Unit Ames Municipal Electric System

**Feature ID**  
CCR Impoundment

**Observation Date**  
December 9, 2020

<b>D.</b>	<b>DOWNSTREAM SLOPE AND TOE</b>	<b>YES</b>	<b>NO</b>	<b>N/A</b>
1.	Are any of the following present: erosion, slides, cracks, depressions, bulges, or sloughing? If so, describe:	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2.	Are seeps present? If so, describe flow and location:	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3.	Is rip rap present? If so, describe condition:	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4.	Are animal burrows present?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5.	Is vegetation in good condition?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.	Is water flowing from internal drains?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>E.</b>	<b>SPILLWAYS: ERODABLE CHANNEL</b>	<b>YES</b>	<b>NO</b>	<b>N/A</b>
1.	Are any of the following present: erosion, slides, cracks, depressions, bulges, or sloughing?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2.	Is vegetation in good condition?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3.	Is there any debris in the channel?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4.	Is rip rap continuous and in good condition?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>F.</b>	<b>SPILLWAYS: STRUCTURES AND OUTLET PIPES</b>	<b>YES</b>	<b>NO</b>	<b>N/A</b>
1.	Are there any restrictions or obstructions (debris, vegetation, trees)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2.	Any observed distress to structure?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3.	Any deterioration of outlet pipe? Visual only	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4.	Any erosion where outlet pipe exits the embankment? If so, describe:	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>





Appendix B  
Photographs

# Coal Combustion Residuals Impoundment Annual Site Observation Photographs

**Facility Name**  
CCR Ash Unit Ames Municipal Electric System

**Feature ID**  
CCR Impoundment


**Site Observation Date**  
December 9, 2020




**Photo 1: 2019 East Ash sluice pipe to Ash Pond Receiving Ditch**



**Photo 2: 2020 East Ash sluice pipe to Ash Pond Receiving Ditch**



**Photo 3: 2019 North dike crest view east along Ash Pond**



**Photo 4: 2020 North dike crest view east along Ash Pond**

# Coal Combustion Residuals Impoundment Annual Site Observation Photographs

**Facility Name**  
CCR Ash Unit Ames Municipal Electric System

**Feature ID**  
CCR Impoundment

**Site Observation Date**  
December 9, 2020



**Photo 5: 2019 North dike interior slope view west along ash pond**



**Photo 6: 2020 North dike interior slope view west along ash pond**



**Photo 7: 2019 Erosion along inside slope south embankment**



**Photo 8: 2020 Erosion along inside slope south embankment**

# Coal Combustion Residuals Impoundment Annual Site Observation Photographs

**Facility Name**  
CCR Ash Unit Ames Municipal Electric System

**Feature ID**  
CCR Impoundment

**Site Observation Date**  
December 9, 2020



**Photo 9: 2019 Outside slope north embankment viewing west.**



**Photo 10: 2020 Outside slope north embankment viewing west.**



**Photo 11: 2019 Ash pond outlet structure**





**Photo 12: 2020 Ash pond outlet structure**

# Coal Combustion Residuals Impoundment Annual Site Observation Photographs

**Facility Name**  
CCR Ash Unit Ames Municipal Electric System

**Feature ID**  
CCR Impoundment

**Site Observation Date**  
December 9, 2020



# Coal Combustion Residuals Impoundment Annual Site Observation Photographs

**Facility Name**  
CCR Ash Unit Ames Municipal Electric System

**Feature ID**  
CCR Impoundment

**Site Observation Date**  
December 9, 2020



**Photo 17: 2019 Gauge located within pump house (CW-2)**



**Photo 18: 2020 Gauge located within pump house (CW-2)**



**Photo 19: 2019 Example of vegetative growth to be removed on northeast corner of the ash pond.**



**Photo 20: 2020 Example of vegetative growth to be removed on northeast corner of the ash pond.**

# Coal Combustion Residuals Impoundment Annual Site Observation Photographs

**Facility Name**  
CCR Ash Unit Ames Municipal Electric System

**Feature ID**  
CCR Impoundment

**Site Observation Date**  
December 9, 2020



**Photo 21: 2019 Animal impacts. See Area 1 on aerial photo.**



**Photo 22: 2020 Area of previously noted animal impacts. See Area 1 on aerial photo.**



**Photo 23: 2019 Erosion on inboard slope southeast portion of the ash pond from south looking northeast. See Area 2 for location.**



**Photo 24: 2020 Erosion on inboard slope southeast portion of the ash pond from west looking along the south/southeast. See Area 2 for location.**

# Coal Combustion Residuals Impoundment Annual Site Observation Photographs

**Facility Name**  
CCR Ash Unit Ames Municipal Electric System

**Feature ID**  
CCR Impoundment

**Site Observation Date**  
December 9, 2020



**Photo 25: 2019 Ash sluice pipe to West Ash Pond Receiving Ditch**



**Photo 26: 2020 Ash sluice pipe to West Ash Pond Receiving Ditch**



**Photo 27: 2019 Typical groundwater monitoring well installed in June 2018.**



**Photo 28: 2020 Typical groundwater monitoring well installed in June 2018.**



# Coal Combustion Residuals Impoundment Annual Site Observation Photographs

**Facility Name**  
CCR Ash Unit Ames Municipal Electric System

**Feature ID**  
CCR Impoundment

**Site Observation Date**  
December 9, 2020



**Photo 29: 2019 Pipe structure connecting west channel to northern area in the ash pond.**



**Photo 30: 2020 Pipe structure connecting west channel to northern area in the ash pond.**



**Photo 31: 2019 SEP floor drain and cooling tower blowdown discharge pipe into the north side of north storage area in the ash pond.**



**Photo 32: 2020 SEP floor drain and cooling tower blowdown discharge pipe into the north side of north storage area in the ash pond.**

# Coal Combustion Residuals Impoundment Annual Site Observation Photographs

**Facility Name**  
CCR Ash Unit Ames Municipal Electric System

**Feature ID**  
CCR Impoundment

**Site Observation Date**  
December 9, 2020



**Photo 33: 2019 Chain link fence installed around perimeter of the ash pond property.**



**Photo 34: 2020 Chain link fence installed around perimeter of the ash pond property.**